

ACS.CMET1 SAFETY ASSESSMENT CRITERIA INITIAL EMERGENCY SERVICE PROVIDER AND GAS METER INSTALLER LOW PRESSURE DIAPHRAGM AND ROTARY DISPLACEMENT METER INSTALLATIONS NATURAL GAS

ACS.SMB.004.AC.TABLE 2.CMET1. INITIAL

CMET1 INITIAL

CMET1 Re-assessment is contained in CESP1; CMA1; CMA2 LS (Part C).

Introduction

Tests gas safety competence to install, commission, service, maintain and exchange LP diaphragm and RD meter installations.

Candidates holding CMET1 are also deemed to hold MET4.

CBs and ACs may adopt Competence and Criteria numbering different to that used in this document.

CB and AC documentation may adopt wording for criteria different to that used in this document, provided the meaning is unaffected.

Range

Primary meter installations incorporating diaphragm or rotary displacement meters without by-pass and of badged capacity > $6 \text{ m}^3/\text{h} \le 1076 \text{ m}^3/\text{h}$ and where the inlet pressure under normal gas supply conditions does not exceed 75 mbar and a meter regulator is to be installed.

This Assessment does not address meter installations that are not connected directly to and downstream of the ECV, nor does it address those that are not adjacent to the ECV. Work on such installations requires CMET2.

This Assessment does not address meter installations that are not Standard Designs, as defined in IGEM/GM/6 Edition 2 except a by-pass is included. IGEM/GM/6 Edition 2 no longer includes by-passes in its scope. New installations with a by-pass are covered by CMET2. However, this assessment continues to include the safe operation of by-passes to address existing installations.

Pre-requisites

COCN1 or CMA1 or CESP1 or COCNPI1LS + ICPN1 + TPCP1 or TPCP1A. or QCF or S/NVQ.

Engineers holding TPCP1 are deemed competent to work to IGE/UP/1, IGE/UP/1A, and IGEM/UP/1C.

Exclusions

Calculating gas load; design; construction/installation of meter boxes, compartments or housing; installation or replacement of ECV, service valves or their operation; meter removal from site and subsequent disposal; testing by OFGEM, and theft of gas.

Certification in this assessment does not of itself confer approval as an 'OAMI' registered gas meter installer.

References and normative documents

MIs.

- HSL56
- GIUSP
- IGEM/GM/6 Edition 2
- IGE/GM/8 Parts 1 to 5

ACS.SMB.004.AC.TABLE 2.CMET1. INITIAL

• IGE/UP/2 Edition 2.

ACS.SMB.003.ACDND indicates those Normative Documents that should be held by ACs.

Abbreviations

AC. Assessment Centre ECV. Emergency control valve GT. Gas transporter I. Initial LP. Low pressure MIs. Manufacturer's/manufacturers' instructions MOV. Meter outlet valve Ref. Reference.

PERF	ORMANCE CRITERIA	REF	I
1.	check ECV operates correctly		\checkmark
2.	confirm connected appliances are of the 'standard type'		\checkmark
3.	check all components are fit for use and purpose		
3(a).	check all components for obstructions		V
	check pressure in service pipe is LP		V
4.	isolate gas supply prior to work		√
5.	remove plug/cap from ECV		√ √
6.	position U65 meter correctly		√
7.	assemble and install all components of meter installation		v
8.			v
9.			
10.			
	. Existing installations with by-pass		
(i)	recognise as 'not a standard design'		\checkmark
(i) (ii)	carry out correct operation of by-pass to exchange meter while maintaining gas supply		v
(1)	to appliances, inc. reading meter		\checkmark
(iii)	seal by-pass valve		v v
11.	criteria removed – covered in 7		v
12.	criteria removed – covered in 7		
13.	position RD1 meter correctly		
13.	assemble and install all inlet supply components of meter installation		
			 √
	install commissioning filter/strainer		
15.	adequately support pipework		
16.	install and level meter		
17.	assemble and install all outlet components		\checkmark
18.	criteria removed – covered in 7		/
19.	fill RD1 meter to MIs		
20.	test RD1 meter installation for tightness		\checkmark
21.	purge RD1 meter installation of air		
22.	commission U65 to MIs and:		\checkmark
	(i) observe meter for faulty operation		
	(ii) apply necessary notices and labels		,
23.	set meter regulator and seal		
24.	remove commissioning filter/strainer. Re-test and purge.		\checkmark
KNO	WLEDGE AND UNDERSTANDING	REF	I
1.	completion of commissioning reports		
1(a).	recognition of meter installations not in scope of IGEM/GM/6 Edition 2 i.e.:		
	(i) containing a by-pass of the meter and/or of the regulator		
	(ii) not of Standard Design		\checkmark
	(iii) outside pressure and design capacity scopes		
	(iv) having non-standard appliances fitted downstream		
1(b).			\checkmark
	design of any purpose-built housing		
2.	labelling		\checkmark
3.	cross bonding for meter installations		\checkmark
4.	routine maintenance of meters		\checkmark

ACS.SMB.004.AC.TABLE 2.CMET1. INITIAL

6.	routine maintenance of filters and strainers	\checkmark
7.	recognition of meter faults	\checkmark
8.	safety requirements for removal of meters	\checkmark
9.	documentation when opening by-pass valves	\checkmark
10.	sealing meter regulators	\checkmark
11.	provision of MOV	\checkmark
12.	pressure terms used in IGEM/GM/6 Edition 2	\checkmark