

ACS.ICPN1 SAFETY ASSESSMENT CRITERIA INITIAL AND RE-ASSESSMENT NON-DOMESTIC NATURAL GAS &LPG PIPEWORK & FITTINGS

ACS.SMB.004.AC.TABLE4.ICPN1.INITIAL & RE-ASSESSMENT

ICPN1 INITIAL & RE-ASSESSMENT

Introduction

Tests gas safety competence in first fixing of non-domestic installation pipework.

CBs and ACs may adopt Competence and Criteria numbering different to that used in this document.

CB and AC documentation may adopt wording for criteria different to that used in this document, provided the meaning is unaffected.

Range

Work on non-domestic pipework up to a maximum operating pressure of 16 bar

Steel, CSST, copper pipework and PE transitional fittings of diameter > 35 mm $(1\frac{1}{4}'')$.

Electro-fusion jointing of PE pipework is covered in EFJLP1.

Pre-requisites

Initial

Any of COCN1; CCCN1; COCNPI1 LS; CCLNG1 or any of CCN1; CCLP1; CESP1; CMA1 or QCF or S/NVQ alternative.

Re-assessment

ICPN1.

Exclusions

Competence for work above 16 bar including additional clauses included in edition 3 of the standard e.g. 'hot tapping' must be covered by a suitable Training and Assessment programme delivered via a Certification Body.

Penetrating or making good of walls floors or ceilings, application of pipework protection, work on gas service pipes, welding of steel joints, butt or electro-fusion of PE joints, installation of main equipotential earth bonding, digging or back filling of trenches.

Aspects of connection of pipework to a gas supply, introduction of any gas to the pipework, tightness testing or commissioning of pipework, appliances or equipment are covered by other Gas Safety Assessments. Installation of, and associated work on, boosters is covered by BMP1.

Normative and reference documents

MIs.

All relevant documents as listed in the Legislative, Normative & Informative Document List (LINDL), inc.:

- HSL56
- IGEM/G/1
- IGEM/UP/2 Edition 3
- BS 1710
- UKLPG CoP22
- GIUSP.

ACS.SMB.003.ACRND identifies Normative Documents that should be held by ACs.

Abbreviations

Issue 5.1 © ACS.SMB

AC. Assessment Centre CB. Certification Body CSST. Corrugated stainless steel tube I. Initial R. Re-assessment Ref. Reference.

PER	FORMANCE CRITERIA	REF	1	R
1.	join CSST		\checkmark	\checkmark
2.			í	
3.	join steel pipe using taper threaded appropriate fittings, jointing compounds,		\checkmark	
4	anaerobic sealants and tapes		/	
4.	join steel pipe using flanges and appropriate jointing material			
5. 6.	join steel pipe using semi rigid compression couplings, methods and agents join copper pipe using capillary end feed fitting, method and agents			
<u>0.</u> 7.	connect PE pipe to steel pipe using appropriate transitional fittings, methods			
<i>'</i> .	and agents		v	
8.	connect thermal expansion bellows between two pieces of steel pipework,		\checkmark	
0.	supported with restraining and alignment ties		v	
9.	join stainless steel pipe/copper pipe with appropriate pressed joints and tools			
10.	check jointing work carried out is gas tight (method at AC discretion)		V	
11.	install bonding strap or permanent continuity bond correctly across an		\checkmark	
	appropriate flange/adaptor or semi rigid coupling			
12.	select correct isolation valves to MIs and for application		\checkmark	
13.	inspect pre-installed pipework and identify correct/incorrect jointing			\checkmark
	WLEDGE & UNDERSTANDING			
0a	acronyms and abbreviations contained within IGEM/UP/2		V	
0b	requirements and sizing for pressure test and purge points		\checkmark	\checkmark
1.	steel pipe and fittings; in particular flange categories		\checkmark	
2.	limitations on nominal bores for jointing steel pipework		\checkmark	\checkmark
3.	limitations on use of CSST		\checkmark	\checkmark
3a	checking synthetic cover of CSST for damage in accordance with MIs		\checkmark	\checkmark
3b	bending CSST within limitations of bend radii in accordance with MIs		\checkmark	\checkmark
3c	brazing copper capillary fittings		\checkmark	\checkmark
3d	limitations of compression coupling joints copper pipework		\checkmark	\checkmark
4.	flexible and semi-rigid connections		\checkmark	
5.	jointing and cleaning agents for steel, copper and PE pipework		\checkmark	\checkmark
6.	pipe supports, clips and fixings for steel, copper and PE		\checkmark	-
7.	types and selection of manual isolation valves		\checkmark	
8.	positioning of manual isolation valves			
9.	pipe sizing to maximum gas flow rate requirements – inc. theoretical exercise		· √	
10.	thermal expansion of long lengths of pipework		· √	
11.	copper pipe and fittings		v v	
12.	colour coding, banding and labelling (direction) of pipework			\checkmark
13.	preparation of pipework installation drawings and use of correct legends		$\overline{}$	v
14.	equipotential/cross bonding			
14a.				
15.	ventilation for pipework in building service ducts, suspended ceiling/floors			
15a.			v √	
16.	buried pipework related to depth of cover and distance from buildings		v √	V
16a.			 √	
10a. 17.	installation of automatic isolation valves			
18.	requirement, speed of operation and types of automatic isolation valve			
19.	HSL56. Reg. 24 Large consumers (1) to (3) inclusive			
20.	location and limitations on use of pressed joints with stainless steel or copper			
20.	pipework		v	
21.	PE pipe and fittings		\checkmark	
22.	effects of vibration from appliances and equipment		· √	
23.	Awareness of Hazardous Area Classification	1		