



**ACS.DAH1
SAFETY ASSESSMENT CRITERIA
INITIAL & RE-ASSESSMENT.
DOMESTIC
NATURAL GAS & LPG
DUCTED AIR HEATERS**

DAH 1**INITIAL & RE-ASSESSMENT****Introduction**

Tests gas safety competence to install, commission, exchange, disconnect, service, repair and break down domestic gas fired ducted air heaters of heat input ≤ 70 kW.

CBs may adopt Competence and Criteria numbering different to that used in this document.

CB documentation may adopt wording for criteria different to that used in this document, provided the meaning is unaffected.

Appliance range

up flow, down flow and horizontal flow models.

Pre-requisites

Initial

CCN1, CCLP1, equivalent changeover combination or equivalent aligned QCF or S/NVQ

Re-assessment

DAH1, Group Competency Certificate for DAH1.

Exclusions

Distribution duct work, grilles, building and electricity.

References and normative documents

Appliance MIs.

All relevant documents as listed in the Legislative, Normative & Informative Document List (LINDL), inc.:

- HSL56
- BS 5864- 2019
- GIUSP.
- IGEM/UP/17

ACS.SMB. 003.ACDND identifies Normative Documents that should be held by ACs.

Abbreviations

AC. Assessment Centre

FSD. Flame supervision device

I. Initial

MIs. Manufacturer's/manufacturers' instructions

OP. Operating pressure

Ref. Reference.

PERFORMANCE CRITERIA		REF	I	R
1.	check location, compartment construction and ventilation meet current requirements		✓	
2.	check appliance assembly is complete and fit for use and purpose		✓	✓
2a	check gas supply pipe in acceptable position for appliance			✓
2b	check appliance and fittings are installed using appropriate materials and fittings, to MIs and Normative Documents			✓
3.	isolate gas supply prior to work		✓	✓
3a	inspect and test burners, injectors, primary airports, filters, heat exchanger, flue-ways, ignition, FSD, thermostats and other gas safety components for correct operation to MIs			✓
5.	position replacement heater in compartment		✓	
6.	size, locate and install plenum base to fit replacement appliance		✓	
7.	size, locate and Install return air duct to fit replacement appliance (OQ/PAWS SCENARIO for RS models, if O/ F model not available to cover install provision & return air requirements)		✓	
8.	make a suitable rigid connection between gas point and appliance		✓	
9.	connect open flue or room sealed flue assembly to appliance		✓	✓
10.	re-establish gas supply		✓	✓
11.	check work carried out is gas tight		✓	✓
12.	check appliance is correctly located, level and stable		✓	
13.	dismantle and clean appliance operational gas safety components, using appropriate cleaning methods and agents, e.g. burners, injectors, primary air ports, ignition devices, thermostats, taps, FSDs and air filters		✓	
14.	commission appliance:			
(i)	purge of air		✓	✓
(ii)	check operating pressure and or heat input at appliance		✓	✓
(iii)	check burner flame picture, stability and ignition are correct		✓	✓
(iv)	check user controls are operating correctly		✓	✓
(v)	check safety control devices are operating correctly		✓	✓
(vi)	check temperature controls are operating correctly		✓	✓
(vii)	check plenum/return air ducts are fixed correctly and adequately sealed		✓	✓
(viii)	check flue is correctly clearing products of combustion		✓	✓
(x)	ensure appliance safe to use		✓	✓
15.	identify defects on gas safety components		✓	✓
15a	carry out combustion performance analysis to MIs and record (OQ or PAWS) if not practically carried out		✓	✓
16.	explain safe operation and use of appliance		✓	✓
KNOWLEDGE & UNDERSTANDING		REF	I	R
1.	identifying unsafe AR & ID Installation conditions		✓	✓
2.	diagnosing gas safety faults		✓	
3.	causes and effects of split heat exchangers and methods to identify		✓	
4.	suitable and unsuitable locations/compartments – fire proofing		✓	
5.	air filters and their effects on appliance		✓	
6.	requirements when combustion air is supplied by heater's circulating fan		✓	
7.	condensate removal and disposal		✓	
8.	CO and combustion ratio checks using an ECGA when commissioning a condensing appliance incorporating air/gas ratio control valve technology		✓	✓
9.	2 or more domestic appliances fitted within a single space with an aggregate total in excess of 70kW (i.e. setting a 'domestic' demarcation)		✓	✓