



**ACS.CoDNESP1 (CCN1 to CESP1)  
SAFETY ASSESSMENT CRITERIA  
INITIAL & RE-ASSESSMENT  
EMERGENCY SERVICE PROVIDER  
&/OR GAS METER INSTALLER  
NATURAL GAS**

**CoDNESP1****INITIAL & RE-ASSESSMENT****Introduction**

Tests gas safety competence for those holding CCN1 who intend to carry out work for an ESP, dealing with gas emergencies downstream of the ECV/MIV.

Comprises:

5. Installation of pipework and fittings
8. Unsafe situations, use of emergency notices and warning labels
9. Operation and positioning of emergency isolation controls and valves (in ND premises)
- 4/12. Ventilation/chimney standards (ND)
15. Re-establish existing gas supply and relight appliances (ND).

CBs may adopt Competence and Criteria numbering different to that used in this document.

CB documentation may adopt wording for criteria different to that used in this document, provided the meaning is unaffected.

**Range**

All domestic/non-domestic gas fittings and appliances.

**Pre-requisites*****Initial***

CCN1 or  
QCF or S/NVQ.

***Re-assessment***

CCN1  
+  
CoDNESP1.

**References and normative documents**

MIs.

All relevant documents as listed in the Legislative, Normative & Informative Document List (LINDL), inc.:

- HSL56
- GIUSP.

ACS.SMB. 003.ACDND identifies Normative Documents that should be held by ACs.

**Abbreviations**

AC. Assessment Centre  
AECV. Additional emergency control valve  
CSST. Corrugated stainless steel tube  
ECV. Emergency control valve  
I. Initial  
MI. Manufacturer's/manufacturers' instructions  
MIV. Meter inlet valve  
MOP. Maximum operating pressure  
ND. Non-domestic  
R. Re-assessment  
Ref. Reference.

**5. Installation of pipework and fittings. Pipe sizes: 28 mm to 100 mm**

<b>PERFORMANCE CRITERIA</b>	<b>REF</b>	<b>I</b>	<b>R</b>
1. join steel pipe using flanges and appropriate jointing material		✓	✓
2. join CSST		✓	✓
3. check synthetic cover of CSST for damage		✓	✓
4. bend CSST within limitations of bend radii		✓	✓
5. recognise PE pipe is connected to steel pipe using appropriate transitional fittings, methods and agents		✓	✓
6. join stainless steel/copper pipe with appropriate pressed joints and tools		✓	✓
7. Confirm all work is appropriately tested for tightness		✓	✓
<b>KNOWLEDGE AND UNDERSTANDING</b>	<b>REF</b>	<b>I</b>	<b>R</b>
1. steel pipe and fittings for ND applications, in particular flange categories		✓	✓
2. stainless steel pipe/copper pipe joined with appropriate pressed joints and tools		✓	✓
3. limitations on use of CSST		✓	✓
4. brazing copper capillary fittings		✓	✓
5. limitations of compression coupling joints with copper non-domestic pipework		✓	✓
6. limitations on nominal bores for jointing steel pipework		✓	✓
7. purpose and suitability to the use of non-contact voltage tester		✓	✓

**8. Unsafe situations, use of emergency notices and warning labels**

<b>KNOWLEDGE AND UNDERSTANDING</b>	<b>REF</b>	<b>I</b>	<b>R</b>
1.			
2. GIUSP: ND installations		✓	✓
3. HSL56: Reg.15 Meters – emergency notices 15 (1) & (2)		✓	✓

**9. Operation and positioning of emergency isolation controls and valves (ND premises)**

<b>KNOWLEDGE AND UNDERSTANDING</b>	<b>REF</b>	<b>I</b>	<b>R</b>
1. emergency isolation valves		✓	✓
2. types of emergency isolation valves used		✓	✓

**4/12. Ventilation and chimney standards (ND)**

<b>KNOWLEDGE AND UNDERSTANDING</b>	<b>REF</b>	<b>I</b>	<b>R</b>
<b>Classification of gas flue systems:</b> flueless, open flue, room sealed			
<b>ND heating appliance ventilation and chimney:</b>			
<b>1. terminal types and positions for Type B open/natural draught chimneys;</b>			
(i) fan diluted flues		✓	✓
(a) dilution air intakes		✓	✓
(b) discharge point			✓
(ii) flueing for balanced compartments for open flued appliances		✓	✓
(iii) common flue /chimney construction requirements - suitable materials for large chimneys		✓	✓
(iv) flue dampers and stabilisers		✓	✓
(v) testing natural draught flues		✓	✓
2. identify installation of adequate and inadequate heating ventilation		✓	✓
3. ventilator/grille locations/positions for ND heating appliances		✓	✓
3a identification and installation of intumescent air vents		✓	
4. safety interlocks between ventilation fans and gas appliances		✓	✓
5. recognise ventilation requirements for mechanical ventilation of Type B2 (forced draught) boilers (inlet and extract)		✓	✓
6. calculate natural ventilation at high and low level direct to outside air for Type B boilers in plant rooms and heated spaces:		✓	✓
(ii) calculate natural ventilation at high and low level direct to outside air for Type B boilers in plant rooms and heated spaces enclosures		✓	✓
<b>ND laundry exhaust duct and ventilation:</b>			
1 calculate individual exhaust duct requirements		✓	✓
2. siting of exhaust ducts and preferred termination procedures		✓	✓
3. calculate individual equipment ventilation		✓	✓
4. calculate multi-equipment ventilation		✓	✓
<b>PERFORMANCE CRITERIA</b>	<b>REF</b>	<b>I</b>	<b>R</b>

1.	recognise suitable overhead canopy extraction for ND catering appliances		✓	✓
2.	identify installation of inadequate ventilation in ND situations		✓	✓

<b>KNOWLEDGE AND UNDERSTANDING</b>		<b>REF</b>	<b>I</b>	<b>R</b>
1.	<b>HSE – ventilation of kitchens in ND catering establishments:</b>			
(i)	replacement air		✓	✓
(ii)	canopy performance		✓	✓
(iii)	dealing with interlocks fitted with overrides		✓	✓
(iv)	recognition of when canopy performance tests are to be carried out		✓	✓
(v)	flueing systems		✓	✓
(vi)				
(vii)				
(viii)	ventilation for internal kitchens		✓	✓

### 15. Re-establish existing gas supply and relight appliances (ND)

<b>PERFORMANCE CRITERIA</b>		<b>REF</b>	<b>I</b>	<b>R</b>
1.	check installation is gas tight		✓	✓
2.	re-establish gas supply		✓	✓
3.	<b>visually check appliance(s) and re-light inc.:</b>			
(i)	purge system and appliances of air		✓	✓
(ii)	light appliance(s)		✓	✓
(iii)	confirm satisfactory operation of user controls		✓	✓
(iv)	inspect appliance installation(s) visually for unsafe situations		✓	✓